

## **CITY OF ELK GROVE DRAINAGE NOTES**

1. ALL CONSTRUCTION AND MATERIALS FOR DRAINAGE SHALL BE IN ACCORDANCE WITH THE CURRENT APPROVED VERSION OF THE CITY OF ELK GROVE STANDARD CONSTRUCTION SPECIFICATIONS AND DRAWINGS. WHERE INCONSISTENCIES EXIST THE LATEST EDITION SHALL TAKE PRECEDENCE.
2. THE MINIMUM COVER REQUIREMENTS DURING CONSTRUCTION SHALL BE 4-FEET FOR PLASTIC PIPE, AND 3-FEET FOR REINFORCED CONCRETE PIPE.
3. THE CONTRACTOR SHALL PLACE THE PROPER STRENGTH PIPE IF TRENCH CONDITIONS ENCOUNTERED DIFFER FROM THE DESIGN TRENCH.
4. STORM DRAIN PIPES IN THE PUBLIC RIGHT-OF-WAY (ROW) AND DRAINAGE EASEMENTS SHALL CONFORM TO SECTION 38 OF THE CITY OF ELK GROVE STANDARD CONSTRUCTION SPECIFICATIONS.
5. STORM DRAIN MANHOLES SHALL BE TESTED IN CONFORMANCE WITH SECTION 39 OF THE CITY OF ELK GROVE STANDARD CONSTRUCTION SPECIFICATIONS.
6. RESILIENT CONNECTORS, IN CONFORMANCE WITH SECTION 39-2.01 OF THE CITY OF ELK GROVE STANDARD SPECIFICATIONS AND CITY OF ELK GROVE STANDARD DRAWING SD-7 ARE REQUIRED AT PRE-CAST MANHOLE AND PIPE CONNECTIONS. WATER STOPS ARE REQUIRED AT CAST-IN-PLACE MANHOLE AND PIPE CONNECTIONS.
7. ALL DRAINAGE INLETS IN THE PUBLIC RIGHT-OF-WAY (ROW) AND DRAINAGE EASEMENTS SHALL HAVE A PERMANENT STORM DRAIN MESSAGE "NO DUMPING – FLOWS TO CREEK" OR OTHER APPROVED MESSAGE CONSISTENT WITH CITY OF ELK GROVE STANDARD DRAWING SQ-10.1. AND SQ-10