



NOTES:

1. 5' MINIMUM REMOVAL REQUIRED WHEN TRENCH IS PERPENDICULAR OR ANGULAR TO FLOW OF TRAFFIC.
2. 1' MINIMUM T-SECTION (PER SIDE).
3. SEE ST-7 FOR GENERAL NOTES.
4. WHERE EXISTING AC DEPTH IS LESS THAN 2.5 INCHES, REMOVE FULL DEPTH, REPAVE AT 4" MIN.

**GRINDING SHALL BE TO THE GUTTER LIP FOR DISTANCES LESS THAN 3 FEET.

DATE: 10/18/2007		NOT TO SCALE		CITY OF ELK GROVE - PUBLIC WORKS		APPROVED BY:			
REVISION	BY	APPROVED	DATE	CITY ENGINEER					
				<p style="margin: 0;">TRENCH BACKFILLING AND RESURFACING</p> <p style="margin: 0;">PCI < 50</p>				DRAWING NUMBER	
									ST - 4