

STREET CLASSIFICATION	RIGHT - OF - WAY WIDTH	STREET LIGHT SUB-TYPE (SERIES)	STANDARD MOUNTING HEIGHT	MAXIMUM SPACING** (ONE SIDE ONLY)
SPECIAL THOROUGHFARE	130'	A	30' - 9"	180'
THOROUGHFARE	108'	A	30' - 9"	220'
ARTERIAL	84'	A	30' - 9"	220'
				MAXIMUM SPACING** (TWO-SIDES)
MAJOR COLLECTOR	74'	A*	30' - 9"	220'
	70'	A*	30' - 9"	220'
COLLECTOR	60'	A*	30' - 9"	220'
	56'	B	21'	180'
RESIDENTIAL	50'	B	21'	200'
	40'	B	21'	240'

NOTES:

1. WATTAGE AND MODEL NUMBER FOR LIGHT EMITTING DIODE (LED) LAMP SHALL BE SPECIFIED ON THE PLANS. EQUIPMENT SHALL CONFORM TO CITY OF ELK GROVE APPROVED EQUIPMENT LIST.
2. ILLUMINATION SHALL CONFORM TO STANDARD DRAWING SL-2.
3. SEE SECTION 5-7D, "SPACING," FOR DEFINITIONS OF ONE-SIDE AND TWO-SIDE SPACING.
- *4. SINGLE FAMILY AND DUPLEX FAMILY ZONING SHALL USE SERIES 'B' STREET LIGHT, 21' MOUNTING HEIGHT,, AND 180' SPACING.
- **5. MAXIMUM SPACING MAY BE ADJUSTED AS LONG AS ILLUMINATION CRITERIA ARE MET WITH APPROVAL OF THE ENGINEER.

DATE: 09/22/2007		NOT TO SCALE		CITY OF ELK GROVE - PUBLIC WORKS		APPROVED BY: <i>Robert M. M... ..</i> CITY ENGINEER		10/24/2018 DATE	
REVISION	BY	APPROVED	DATE	COMMON TYPE STREET LIGHT POLE SPACING GUIDE (SERIES 'A'/ SERIES 'B')				DRAWING NUMBER	
								SL - 24	

