



NOTES:

1. SEE STATE STANDARD PLAN ES-2D AND ES-3C FOR STANDARD ANCHOR BOLT PATTERNS AND SIZES.
2. IN UNPAVED AREAS, A RAISED PORTLAND CEMENT PAD SHALL BE CONSTRUCTED IN FRONT OF THE FRONT DOOR OF THE CONTROLLER CABINET (50" W x 48" D x 4" THICK).
3. FRONT DOOR OF THE CONTROLLER CABINET SHALL FACE NORTH OR EAST, WHENEVER FEASIBLE. THE FINAL LOCATION OF THE CONTROLLER CABINET AND SERVICE CABINET SHALL BE APPROVED BY THE CITY ENGINEER.

DATE: 09/22/2017		NOT TO SCALE	
REVISION	BY	APPROVED	DATE

CITY OF ELK GROVE - PUBLIC WORKS

**CONCRETE FOUNDATION FOR
TYPE P CONTROLLER CABINET
AND TYPE III SERVICE CABINET**

APPROVED BY:
Robert Mullock
CITY ENGINEER

10/24/2018
DATE

DRAWING NUMBER
T - 12

