



## REQUEST FOR MEDIUM PRESSURE GAS SERVICE

May 2005 (Revised Dec. 2010)

Medium pressure gas installations are regulated by Chapter 13, Appendix B, of the California Mechanical Code, and by Chapter 12 of the California Plumbing Code.

Concealing of medium pressure gas piping shall be avoided, but if approved, joints shall be welded. The necessary regulators shall be readily accessible, with permanent ladders, catwalks, working platforms and lights as required, for inspection and servicing.

Exposed piping and piping on the roof may be screwed pipe. Regulators on the roof shall be accessible by means of a permanent ladder, as designed for other roof mounted equipment.

Gas cocks shall be approved for the pressure supplied.

Medium pressure gas lines shall be tested at sixty (60) psi, for twenty-four (24) hours with 8" graph test.

Building Address:	
Owner:	
Mechanical Contractor:	Phone No.:
Address:	License No.:

The request for medium pressure gas service, at the above address, has been approved by both the City of Elk Grove Building Safety and Inspection Division and the serving Gas Utility.

The requested demand is \_\_\_\_\_ BTU's per hour.

The pressure requested is \_\_\_\_\_ psi.

\_\_\_\_\_ / \_\_\_\_\_ / 2008  
**(Serving Gas Utility)**

Approved for service: \_\_\_\_\_ / \_\_\_\_\_ / 2008  
**Building Safety & Inspection**