



SECTION
24" DIAMETER TO 36" DIAMETER
C.M.P. INLET

NOTES:

1. LOCATIONS, HEIGHTS, AND LENGTH OF OPENINGS SHALL BE AS SHOW ON THE PLANS.
2. AREA OF OPENING SHALL NOT BE LESS THAN AREA OF OUTFALL PIPE.
3. OUTFALL PIPE TO BE CUT FLUSH WITH INSIDE OF RISER.
4. NOT TO BE USED AS A JUNCTION STRUCTURE.
5. DIAMETER OF RISER PIPE SHALL BE AT LEAST ONE SIZE LARGER THAN OUTFALL PIPE.
6. TO BE USED ONLY WITH THE SPECIFIC APPROVAL OF THE CITY ENGINEER.

RISER DIAMETER, D	H, MAX.	HEIGHT T, MAX.	GAGES (MINIMUM)
24"	4'	8"	0.079"
30"	4'	8"	0.079"
36"	5'	8"	0.109"
42"	8'	12"	0.109"
48"	8'	12"	0.109"
54"	10'	18"	0.109"
60"	10'	18"	0.109"
72"	10'	18"	0.109"

DATE: 01/17/2007		NOT TO SCALE		CITY OF ELK GROVE - PUBLIC WORKS		APPROVED BY:	
				CORRUGATED METAL PIPE DRAINAGE INLET TYPE I		CITY ENGINEER	
				(PG 2 OF 2)		DRAWING NUMBER SD - 21.2	

